IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 152004 PIN# ~~4639345045.194~~ 4639 846415 DATE 8-14-08

OWNER OR APPLICANT Bells Crossing LLC PHONE: Business 704-663-1600 Home

ADDRESS 514 Williamson Rd & Suite 421 Mooresville NC, 28117

LOCATION Perth Rd, TL Bells Crossing, on L

SUBDIVISION Bells Crossing BLOCK / SECTION 3 LOT 194 LOT AREA .76 AC SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .225

Septic Tank: 1000 Gallons: STB 760 Date 11-20

Pump Tank: 1000 Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1011' Linear Feet 537'

No Lines 6 Trench Width 36" Max Trench Bottom Depth 30" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity 25% Red

Repair System Description: LPP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☐ Public ☒ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: 1) Trench bottom is 30" due to so.l conditions 2) French drain must be installed AS shown on lay out

Comments/Conditions:

INITIAL SITE SKETCH

See Attached from Rollins So.l + Environmental Services

AS BUILT SKETCH

CHECKED LINES 1,2 & 3 4-3-13

CHECKED TANK

CHECKED FRENCH DRAIN 4-23-13

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9/12/08 Installed by: CR

Improvement Permit by: date 8-14-08 Operation Permit by: date

Authorization to Construct by: date 2/13/13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK