IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

Owes 4.00

PERMIT# ~~15240S~~ 177330 PIN# ~~4639834045.056~~ 4639855030 DATE 9/24/08

OWNER OR APPLICANT ~~Zion West Developers~~ Bells Crossing PHONE: Business 704 361-1084 Home

ADDRESS 127B Promenade Dr. Mooresville NC 28117

LOCATION Hwy 150 w TR Portland TL Bells Crossing TR St Sophia In Cul de Sac Court

SUBDIVISION Bells Crossing BLOCK / SECTION LOT 66 LOT AREA 1.11 AC SITE CLASS. F5 DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 760 Date 10/21/13

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 400

No Lines 4 @ 100 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: LPP PPGPS

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☐ Individual ☐ Public ☑ Community Well

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave off top so tank is not below 6". Install tank marker

Comments:/Conditions:

6 8

8 6

10 4

e2h

INITIAL SITE SKETCH

See Plan by Michael Atwater & Assoc. Inc.

LS

DECK APPROVED APPEARS TO MEET ALL 1980 R4F SETBACKS 8-26-14

SEE ATTACHED SITE PLAN

Lane Gray REHS

AS BUILT SKETCH

Location of the proposed DECK addition does not appear to impact the existing on-site septic system or well.**NOTE: SEE ATTACHED SITE PLAN

Lane Gray REHS Date: 8-26-14

ICHD Environmental Health Division

APPLICATION # 203690

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 11/00/08

Improvement Permit by: Anthony Cole R.S. date 9/24/08

Authorization to Construct by: C. Bly Jr. date 2/12/13

Installed by: CAROLINA PIPE CLEANING

Operation Permit by: RA date 7-29-13

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK