owes 0 4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# ~~15405~~ 177330 PIN# ~~4639834045.056~~ 4639855030 DATE 9/24/08

OWNER OR APPLICANT ~~Zion West Developers~~ Bells Crossing PHONE: Business 704 361-1084 Home

ADDRESS 127 B Promenade Dr. Mooresville NC 28117

LOCATION Hwy 150 W TR Portland TL Bells Crossing TR St. Sophia Dr Cul de sac Court

SUBDIVISION Bells Crossing BLOCK / SECTION LOT 66 LOT AREA 1.11 AC SITE CLASS. P5 DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 760 Date 10/21/12

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1600 Linear Feet 4100+

No Lines 40/100 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: LOPPERS

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☐ Individual ☐ Public ☑ Community Well

☑ Gravity ☐ Pressure ☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Shave off top so tank is not below 6". Install tank marker

Comments:/Conditions:

6 8

8 6

10 4

625

INITIAL SITE SKETCH

See Plan by Michael Athwal and Associates, Inc.

L55

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☑ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 11/10/08 Installed by: Carolina Pipe Cleaning

Improvement Permit by: Anthony Cole R.S. date 9/24/08 Operation Permit by: date 7-29-13

Authorization to Construct by: C. Baty date 2/12/13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK