IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # RF 200909

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639-95-5462 *Part of*

APPLICANT: Meritage Homes of NC APPLICANT ADDRESS: 7761 Ballantyne Commons Pkwy Charlotte NC

SITE ADDRESS: 153 Leaning Tower Dr Mooresville PHONE: 704-944-8903 ALT. PHONE:

SITE DIRECTIONS: Hwy 150 W, TR on Perth Rd, TL on Bells Crossing, TR on N. San Agustin Dr, TL on Leaning Tower, Lot on L

SUBDIVISION: Bells Crossing SECTION: LOT # 39 LOT AREA: 1.86 ac DESIGN FLOW: 600 gpd L.T.A.R.: 0.25

Septic Tank ~~1500~~ (gal) STB 964 Date 4-5-14
Pump Tank 1500 (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 9 Linear Ft: 600
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Gravity 25% Reduction
Repair System Description: LPP PPBPS
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☐ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing
No. Bedrooms 5 No. Persons 10 No. Employees
☑ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions: 2/4/14 Checked ST & MD Upper 4 lines.

Built with Basement application has Basement Checked. ST 10FT downhill of basement wall

INITIAL SITE SKETCH

SEE DESIGN BY BATEMAN CIVIL SURVEY COMPANY

APPROVED BY ICHD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 1-30-14 Installed by: Carolina Pipe

IMPROVEMENT PERMIT by: Date: 1-29-14 OPERATION PERMIT by: Date: 5-20-14

AUTHORIZATION TO CONSTRUCT by: Date: 2/4/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK