DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Honey Suckle Creek LLC APPLICATION DATE ___
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ DATE EVALUATED: ___
LOCATION OF SITE: Honeysuckle Creek lot 26 PROPERTY SIZE: ___
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 4-10%	0-6	Bscl vfr	fi sspl sthp	—	48	—	—	PS .3
		6-48	RC sam	fi sl sspl					
2		0-36	wfsgrn LBCl fi	sssp sthp fri sthp	—	—	—	B	PS .25
		36-59	MRYLSA	fi sssp	WH w Rock				
3		0-14	WSGR vfr gsl fri sspl		—	—	—	—	.2 .25 .3
		14-32	MFSGR & CBL fri sspl						
		32-58	WFSGR gsl/CBL fri/fi sp/sssp		fri/firm sap				
4	Alt 1	0-48"	RW/Brw C/Pl m-w SBK		55,59,5E				PS .3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

COMMENTS: ___

2

59
50
45
44
34/33