IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 15221 5 PIN # ~~4639834045~~ 4639941718 DATE 11-12-08

OWNER or APPLICANT Bells Crossing LLC / Rollans PHONE: Business 704 361-1084 Home:

OWNER or APPLICANT ADDRESS 127 B Promenade Dr. Mooresville, NC 28117

LOCATION / DIRECTIONS Perth Rd North

SUBDIVISION Bells Crossing BLOCK / SECTION LOT # 60 LOT AREA DESIGN FLOW 480 gpd L.T.A.R. .3 / .25 Repair Initial

Septic Tank 1000 Gallons: STB 760 Date

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines ~~X~~ 6 Linear Feet 405

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: Gravity - 25% Reduction

Repair System Description: LPP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions Initial Site evaluation done by Rollans Soil & Environmental Services Inc.

~~X~~ 3/28/13 Ashley Rollins left voice mail that he is good with changes made to Drainfield (using 6 lines instead of 5)

Comments / Conditions Used Quick 4 for Drainfield Used 6 lines instead of 5

INITIAL SITE SKETCH

See attached (approved) plan by Rollans Environmental

AS BUILT SKETCH

Installed essentially as Shown.

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 12/16/08

Improvement Permit by: Marie Hutton RS Date 11/17/08

Authorization to Construct by: M. Brady Lewis RS Date 2/12/13

Installed by: Carolina Pipe

Operation Permit by: Marie Hutton RS Date: 3/28/13

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant