IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 152568

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639942181

APPLICANT: MERITAGE HOMES of NC APPLICANT ADDRESS: 7761 BALLANTYNE COMMONS PKWY 103

SITE ADDRESS: 113 BELFRY LOOP. MOORESVILLE NC 28117 PHONE: ALT. PHONE:

SITE DIRECTIONS: PERTH (N) - TL BELLS XING TL BELFRY - ON LT

SUBDIVISION: BELLS CROSSING SECTION: LOT # 98 LOT AREA: .78 DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 1605 Date 2-10-14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 10 9 Linear Ft: 480
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☐ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: DRIP
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence ☐ Business ☐ Other ☐ Slab ☐ Basement w/plumbing
No. Bedrooms 4 No. Persons 8 No. Employees
☑ Crawl Space ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions:

Lower 3 lines inspected by BA 6/18
Upper 6 lines inspected by MD 6/18
& PST Checked MD

INITIAL SITE SKETCH

SEE BATEMAN CIVIL SURVEY PLAN

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 10-1-13 Installed by: Carolina Pipe

IMPROVEMENT PERMIT by: PHILLIPS Date: 8/29/13 OPERATION PERMIT by: Date: 6/18/14

AUTHORIZATION TO CONSTRUCT by: Date: 1-9-14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK