4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 152214 PIN# 4639834045.59 4639-94-2703 DATE 10-28-08

OWNER OR APPLICANT Bells Crossing LLC / ~~Rollan Soil & Env~~ PHONE: Business 704 361-1084 Home

ADDRESS 127B Promenade Dr Mooresville, NC 28117

LOCATION Perth Rd N. TL Bells Crossing lot on right

SUBDIVISION Bells Crossing BLOCK / SECTION LOT 59 LOT AREA 1.0 Acre SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .3 gpd/ft²

Septic Tank: 1000 Gallons: STB 760 Date 9-23

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1215' Linear Feet 405'

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

[X] New System [ ] Repair [ ] Expansion System Type: I II III IV V VI

System Description: Gravity - 25% Reduction

Repair System Description Pump - LP - PPBPS

Maintenance Agreement Required: [ ] Yes [X] No

[X] House/Mod. Home No. Bedrooms 4

[ ] Mobile Home No. Persons

[ ] Business No. Employees

[ ] Other

Water Supply: [ ] Individual [X] Public [X] Community

[X] Gravity [ ] Pressure [ ] Slab [X] Crawl Space [ ] Basement w/plumbing [ ] Basement wo/plumbing

Comments/Conditions: Initial Site Evaluation done by Rollans Soil & Environmental Services, Inc

Comments/Conditions: TANKS TO OTHER SIDE - REDRAW FFE

INITIAL SITE SKETCH

See approved plan by Rollans Soil & Environmental (attached)

AS BUILT SKETCH

66
610
93
104

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 11/08/08 Installed by: CPC

Improvement Permit by: Maria H Rollans RS date 10/28/08 Operation Permit by: Bells date 7-9-13

Authorization to Construct by: date 2/18/13 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK