IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 15221 2

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639943741

APPLICANT: MERITAGE HOMES APPLICANT ADDRESS: 7761 BALLANTYNE PKWY CHARLOTTE 28277

SITE ADDRESS: BELLS CROSSING PHONE: ALT. PHONE:

SITE DIRECTIONS: PERTH RD (N) - TL BELLS CROSSING - ON RT

SUBDIVISION: BELLS CROSSING SECTION: LOT # 58 LOT AREA: 1.12 AC DESIGN FLOW: 480 GPD L.T.A.R.: ~.275

Septic Tank 1000 (gal) STB 760 Date > 28 DAYS
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 6 Linear Ft: 468
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: DRIP
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence ☐ Business ☐ Other ☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing
No. Bedrooms 4 No. Persons 8 No. Employees
Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions:

INITIAL SITE SKETCH

SEE BATEMAN CIVIL

SURVEY COMPANY'S PLAN

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 6-13-13 Installed by:

IMPROVEMENT PERMIT by: Date: 6/12/13 OPERATION PERMIT by: Date: 6-17-13

AUTHORIZATION TO CONSTRUCT by: Date: 6/12/13 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK