IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 152570 PIN # 4639834045 4639-94-4334 DATE 4/9/09

OWNER or APPLICANT Bells Crossing LLC PHONE: Business 704.361.1084 Home:

OWNER or APPLICANT ADDRESS 127 B Promenade Dr. Mooresville, NC 28117

LOCATION / DIRECTIONS Perth Rd. TL Bells Crossing, Lot on Corner @ Bend on Lft.

SUBDIVISION Bells Crossing BLOCK / SECTION — LOT # 100 LOT AREA 0.84 acres DESIGN FLOW 480 gpd L.T.A.R. 0.3

Septic Tank 1600 Gallons: STB 1007 Date 5-18-09

Pump Tank ____ Gallons: P T ____ Date ____

Pump Make ____ Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 4 Linear Feet 400

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth — GRAVITY PRESSURE

☑ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: Gravity 25%

Repair System Description: LPPPBPS

Maintenance Agreement Required ☐ YES ☑ NO

☑ Residence No. Bedrooms 4

☐ Business No. Persons ____

☐ Other No. Employees ____

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☑ Community

Comments / Conditions
* Install on Contour / Maintain all Setbacks
* Initial site evaluation performed by Rollins Soil & Environmental

Comments / Conditions
Drainlines Checked 7/23/09 by WS
Installed Quick 4 in 4-100 ft lines

INITIAL SITE SKETCH

See Attached approved Plan by Rollins Environmental

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: ____ Date ____

Improvement Permit by: Rollins Date 4/9/09

Authorzation to Construct by: Rollins Date 4/9/09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Wayne Cloetzo RS

Operation Permit by: Mauri Adams RS Date: 7/24/09

Existing System Inspected by: ____ Date: ____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant