4639 94 9471

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 152573 PIN # ~~4639 94 9480~~ DATE 07-09-10

OWNER or APPLICANT Bells Crossing LLC PHONE: Business 704-799-8641 Home: 704-496-1735

OWNER or APPLICANT ADDRESS 127 Promenade Dr. Mooresville NC 28117

LOCATION / DIRECTIONS Perth Rd N. TL Bells Crossing at corner of S. San Agustin Dr. 106 S. San Agustin

SUBDIVISION Bells Crossing BLOCK / SECTION ph. 1 LOT # 104 LOT AREA .90 Ac. DESIGN FLOW 600 gpd L.T.A.R. .3 gpd/ft²

Septic Tank 1500 Gallons: STB RST 1014 Date 11-28-10

Pump Tank ____ Gallons: PT ____ Date ____

Pump Make ____ Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 5 Linear Feet 500

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I (II) III IV V VI

System Description: 25% reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 5

☐ Business No. Persons 10

☐ Other No. Employees ____

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

Comments / Conditions 1/21/11 Checked tanks & upper 2 lines
1/24/11 Checked 3rd line 120 ft
2/3/11 Checked 4th line 120 ft
2/7/11 Checked 5th

INITIAL SITE SKETCH

See Plan from SWME approved by ICHD

AS BUILT SKETCH

Installed Quick 4 essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 7/12/10

Improvement Permit by: Judy Melville Date 7-9-10

Authorization to Construct by: Judy Melville Date 7-12-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Wayne Glantz REHS

Operation Permit by: [signature] Date: 2/7/2011

Existing System Inspected by: ____ Date: ____

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant