IREDELL COUNTY HEALTH DEPARTMENT


ENVIRONMENTAL HEALTH DIVISION

PAGE 2: *SITE PLAN WORKSHEET*

SEE THE "SAMPLE SITE PLAN" BELOW. *INCOMPLETE SITE PLANS WILL BE RETURNED TO YOU FOR COMPLETION AND MAY RESULT IN A DELAY IN THE ISSUANCE OF YOUR SEPTIC SYSTEM PERMIT!!!*

Place an (X) beside each item as you complete the site plan:

- (X) Property Line measurements are clearly identified
- (X) All proposed structures are indicated
- (X) Front and side setbacks from property line
- (X) Preferred driveway location and well location
- (X) Area you prefer your septic system to be placed
- (X) North arrow, or other sufficient indicator of direction



Circle N/A on the following if appropriate:

Location of septic systems and wells within 100' of your property	N/A
Location of easements and rights of ways on your property	N/A
Location of any designated wetlands on the property	N/A

USE THIS SPACE TO DRAW YOUR SITE PLAN

Show: proposed house or business footprint, wells, water lines, patios, pools and decks, and any other item that will occupy space on the site

See Attached

Signature: _____ 2-2-15

Property owner or owner's legal representative signature (SIGNATURE REQUIRED) — DATE

LINE SCHEDULE

LINE NUMBER	COLOR	FIELD ELEVATION	LENGTH (FT)	DESIGN LENGTH (FT)
1	BLUE	2.2	27	24
2	YELLOW	3.4	46	36
3	ORANGE	5.7	62	60
4	RED	8.0	63	60
5	BLUE	10.0	60	60
6	YELLOW	11.3	60	60
7	ORANGE	12.9	60	60
8	YELLOW	13.7	25	
9	RED	14.9	73	60
10	BLUE	15.9	62	60
11	YELLOW	17.2	64	60
12	ORANGE	18.9	55	
13	RED	21.0	67	
14	BLUE	22.6	39	
15	PINK	2.6	27	
16	RED	3.5	58	
17	YELLOW	4.5	57	
18	PINK	5.1	51	
19	RED	5.9	48	
20	YELLOW	6.7	45	
21	PINK	7.9	38	
22	RED	8.8	37	

LOT 34 BELLS CROSSING SUBDIVISION

5-BEDROOM ACCEPTED STATUS PRESSURE MANIFOLD SYSTEM
LINES 1-7 & 9-11 TOTAL 540 LINEAR FEET
EZFLOW OR CHAMBER
LTAR 0.3
25% REDUCTION
18" TRENCH DEPTH


5-BEDROOM ACCEPTED STATUS PRESSURE MANIFOLD SYSTEM
LINES 8 & 12-22 TOTAL 547 LINEAR FEET
EZFLOW OR CHAMBER
LTAR 0.275
25% REDUCTION
18" TRENCH DEPTH

NOTE: LINES MAY BE LONGER IN THE FIELD. TRIM TO DESIGNED LENGTH.

FOR GENERAL USE NOT A SURVEY
PRELIMINARY NOT FOR CONSTRUCTION

SOIL PROFILES AND ANALYSIS PROVIDED BY CENTRAL CAROLINA SOIL CONSULTING PLLC

Revised
5-5-15
ALP



Bateman Civil Survey Company
Engineers • Surveyors • Planners
200 N. Main Street, Holly Springs, NC 27540 Ph: 919.577.1080 Fax: 919.577.1081
www.batemancivilsurvey.com info@batemancivilsurvey.com
NCBELS Firm No. C-2378

MeritageHomes

LOT 34
BELLS CROSSING SUBDIVISION
MOORESVILLE, NC
IREDELL COUNTY
REVISED 02/12/15
DATE: 02/02/15 DRAWN BY TMB CHECKED BY: TMB