IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 181573

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4639-95-5894

APPLICANT: Heritage Homes APPLICANT ADDRESS: 11605 N. Community Ln Suite 250 Charlotte NC 28277

SITE ADDRESS: 155 San Agustin Dr N PHONE: 704-319-6577 ALT. PHONE:

SITE DIRECTIONS: Hwy 150 W, TR on Perth Rd, TL on Bells Crossing Dr, TR on San Agustin Dr lot @ end on L

SUBDIVISION: Bells Crossing SECTION: 2 LOT # 26 LOT AREA: 2.33 DESIGN FLOW: 600 gpd L.T.A.R.: 0.3

Septic Tank 1500 (gal) STB 964 Date 8/15/14
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 10 Linear Ft: 524
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: Gravity 25% Reduction
Repair System Description: PM/ 25% Reduction
Maintenance Agreement Required: ☐ YES ☑ NO
☑ GRAVITY ☐ PRESSURE

☑ Residence No. Bedrooms 5
☐ Business No. Persons 10
☐ Other No. Employees
☐ Slab ☐ Crawl Space
☐ Basement w/plumbing ☑ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions:

INITIAL SITE SKETCH

SEE DESIGN BY BATEMAN CIVIL SURVEY COMPANY

APPROVED BY ICHD

AS BUILT SKETCH

TANKS OK
10/28/14 SC

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 3-24-14 Installed by: Carolina Pipe

IMPROVEMENT PERMIT by: Date: 3-24-14 OPERATION PERMIT by: APPROVED Date: OCT 29 2014

AUTHORIZATION TO CONSTRUCT by: APPROVED JUN 13 2014 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK