3,100

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 181575

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

4639-95-7445.000 PIN # ~~4639-95-5402.028~~

APPLICANT: MERITAGE HOMES APPLICANT ADDRESS: 7761 BALLANTYNE COMM. PKWY

SITE ADDRESS: 145 N. SAN AGUSTINE PHONE: 704-309-6577 ALT. PHONE:

SITE DIRECTIONS: BELLS, TR N. SAN AGUSTINE, 3RD ON L

SUBDIVISION: BELLS CROSSING SECTION: 2 LOT # 28 LOT AREA: .9 AC DESIGN FLOW: 600 L.T.A.R.: .3

Septic Tank 1500 (gal) STB Date

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 4 Linear Ft: 565'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 25% RED.

Repair System Description: PANEL

Maintenance Agreement Required: ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 5

☐ Business No. Persons

☐ Other No. Employees

☒ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions:

7/11/14 Checked upper line.

INITIAL SITE SKETCH

SEE PLAN FROM BATEMAN CIVIL SURVEY CO.

APPROVED BY ICHD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 12-4-13 Installed by: Carolina Pipe

IMPROVEMENT PERMIT by: Date: 11-22-13 OPERATION PERMIT by: APPROVED SEP 22 2014

AUTHORIZATION TO CONSTRUCT by: APPROVED JUN 13 2014 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK