N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM


WNER: Honeysuckle Creek LLC APPLICATION DATE _____
DDRESS: _____ DATE EVALUATED: _____
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
OCATION OF SITE: Honeysuckle Creek Lot 46 PROPERTY RECORDED: _____
ATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
YPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 4-20%	0-24	RC ABK	fri SP/SSP	–	49"	–	–	PS .3
		24-49	RCL/Hcly SBK	fri SSP					
2	↓	0-26	RL SBK	fri SP	–	39"	PS	–	PS .3
		26-39	RCL MASBK	fri SSP					
		39-59	SL/L SAP M	fri SSP					
3		0-33	RL SBK	fri/fri SSP	– few SAP	53"	–	–	PS .3
		33-53	RCL MASBK	fri SSP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

OMMENTS: _____


0.60 ac.
0.60 ac.
217.00'
217.00'
217.00'
120.00'
120.00'
120.00'
CCM
S 09°52'21" E 217.58'
S 09°52'21" E 217.58'
S 09°52'21" E 217.58'
LOT49
333 sq.ft.
63 ac.
LOT48
26,040 sq.ft.
0.60 ac.
LOT47
26,040 sq.ft.
0.60 ac.
LOT46
26,040 sq.ft.
0.60 ac.
LOT4
26,040 s
0.60
120.00'
120.00'
120.00'
22.78'
S 84°17'45" W
N 84°17'45" E
N 84°17'45" E
C11
C12
40.59'
120.00'
120.00'
120.00'