N-SITE WASTEWATER SECTION

PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Honeysuckle Creek LLC APPLICATION DATE
DDRESS: DATE EVALUATED:
ROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:
OCATION OF SITE: Honeysuckle Creek lot 44 PROPERTY RECORDED:
ATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other
VALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Septic lot 36A/37A

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	on slight ridge LSS 8-10%	0-14	AC SMK	fi SP	—	50"	—	—	PS .3
		14-50	RC/C MPSM	fr SSSP					
2		0-7	BSCL CR	fr SMSP	—	48"	—	—	PS .3
		7-48	RC ABK/SBK	fi SP					
3		0-20	RC ABK	fi SP	—	48"	PS	—	PS .3
		20-40	RCL MPSBK	fr SSST-from SAP					
		40-61	RSAP M	fi SSSP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948):

EVALUATED BY:
OTHER(S) PRESENT:

OMMENTS:

N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Honeysuckle Creek LLC APPLICATION DATE _____
DDRESS: _____
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: _____
OCATION OF SITE: Honeysuckle Creek lot 37 PROPERTY SIZE: _____
'ATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
VALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
YPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 4-6%	0-33	YRC ABK	FI SP	2 chroma @ 33"+	33	-	33"	I @ ≤ 33"
2		0-12	no matrix - Mixed min & Mats		2 chroma @ 12"+	12"	U -	12"	U
		12-55	CSAP/fine sandy loam w/ FI						
3	SLT/MTN CC	0-32	sch/gr wsbk fri	SS/SP	2 chroma @ 32"+	45	-	32"	I
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____