4-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: Honeysuckle Creek LLC APPLICATION DATE _____
DDRESS: _____ DATE EVALUATED: _____
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
OCATION OF SITE: Honeysuckle Creek lot 40 PROPERTY RECORDED: _____
'ATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
VALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
YPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-31	RBC ABK	fi sa SP -	many, stains 48" → Heavy C		—	.15-.2	.25
		31-54	RYCL WSBK	fri SP SaSP					
2		0-19	RCL ABK	fi SaSP SP					4/per marginal 12-25
		19-42	RCL MWSBK	fri SSSP SaSP					
		42-55	LSAP M	fri SaSP - inc fCL/C		42"	PS	—	
3		0-20	RC ABK	fi SVP			—	—	.15-.2
		20-53	RCL MFSBK	fri SP					
4		0-3	WFSBK RCL	fri SSSP					
		3-19	Somewhat Co-o. to 12" - RCL	fi/ SP/SaSP	few SRB	19"			.3 >12-19"
		19-61	MLSAP fine SL	fri					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

OMMENTS: _____

5) 0-7 MCOP RBC fi fri SSSP
7-23 - WFSBK RBC fri SP, SaSP
23-36 WFGRSBK YRCL fri SSSP few SP 1-2-.25 @ 36" PS
36-57 - LSAP M WFSBK fri few GR → .25 → 36"

6)