# IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140740 PIN# 4639974684 DATE May 18, 2007

OWNER OR APPLICANT Richard Farms LLC / Rollins Homes PHONE: Business _____ Home _____

ADDRESS 227 Hideaway Ln. Mooresville N.C. 28117

LOCATION Forbes Rd(N) to TL Forbes Hill Rd. TL Nesting Quail on left past pit w/ Tall Trees

SUBDIVISION Highland Ridge BLOCK / SECTION _____ LOT 23 LOT AREA 1.65 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 825 Date 3-4-14

Pump Tank: 1000 Gallons; PT 302 Date 2-11-14

Pump Make: Zoeller Model N152 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 840 ± Linear Feet 280

No Lines 4 Trench Width 36" ± Max Trench Bottom Depth 36" Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons _____ No. Employees _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Litters

Shave off old berm in septic system AREA

10/4/13 Reviewed Floor plans, in compliance with Original Septic plan.

INITIAL SITE SKETCH

SEE Plan from Rollins Soil & Env. Services

Comments:/Conditions: ☆ Do Not grade house site. ☆ ST 10' off porch & 8' off house. 5/21/14 Set 2" Pressure 5/32" hole drilled

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 6-7-07 Installed by: Rowan Septic

Improvement Permit by: _____ date 5-18-07 Operation Permit by: _____ date 5-28-14

Authorization to Construct by: _____ date 10/4/13 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK