DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Honeysuckle Creek LLC APPLICATION DATE ___
ADDRESS: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Honeysuckle Creek lot 15 PROPERTY RECORDED: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LSS 10-15%	0-6	BSCL GRAVELLY fr SSSP SO,P			50"	—	—	S .5 -.25
		6-50	RC ARM fr SP SO,P		Common Mott exp				
2		0-6	BSCL GR fr SSSP SO,P			56	—	34"	.25 -.2
		6-34	YRC ARM fr SSSP SO,P		Common Mott exp				
		34-56	White Gray C Mass fr VSSP		2 chromas @ 34"+				Ue 34"+
3		0-30	BSCL/SC white fr SSSP SO,P						≥ 34" (4) @ 34"+
		30-36	BC ARM fr SP SO,P		2 chromas @ 36"+			36"	
		36-60	Gray/White Clay exp VFI VSSP						
4		0-36	RC ARM fr SP						.3 .3
		36-60	Red/Yel SAP fr SSSP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

COMMENTS: ___

5) 0-12 Bsl w SAP fr SSSP SO,P .25 to 32"
12-50 RC Arm fr SP SO,P 2 chromas — Ue 32"
50-60 Gray/White C Mass fr SP @ 32"+