IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 14804 | PIN # 4644-08-3861 | DATE 6-8-09

OWNER or APPLICANT JOE + ANDREA NEMECHEK | PHONE: Business 704-663-4189 | Home:

OWNER or APPLICANT ADDRESS 195 KNOXVIEW LN MOORESVILLE, NC 28117

LOCATION / DIRECTIONS 115, TR LANGTREE, TL INTO KINGS LANDING, 199

SUBDIVISION KINGS LANDING | BLOCK / SECTION | LOT # 5 | LOT AREA .831 AC | DESIGN FLOW 360 | L.T.A.R. .25 (.3) REPAIR

Septic Tank 1000 Gallons: STB 526 Date 2005
Pump Tank Gallons: P T Date
Pump Make Model Serial #
Nitrification Field No Fields 1 No Lines 7 Linear Feet 364'
Trench Width 36" Max. Trench Bottom Depth 28" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type (II) III IV V VI
System Description: GRAVITY 25% REDUCTION
Repair System Description: LP-PANEL BLOCK
Maintenance Agreement Required ☐ YES ☒ NO INITIALLY
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply
☐ Private
☐ Public
☒ Community

Comments / Conditions 1) MAINTAIN ALL REQUIRED SETBACKS 2) 28" MAX TRENCH BOTTOM 3) GUTTER OR ANY OTHER DRAIN MUST BE MIN 15' FROM DRAIN LINES

Comments / Conditions NOTE FOR REPAIR - FILL MATERIAL MUST BE REMOVED BEFORE REPAIR IS INSTALLED

INITIAL SITE SKETCH

SEE ATTACHED PLAN FROM ROLLANS SOIL + ENVIRONMENTAL SERVICES

AS BUILT SKETCH

1 PIECE 1000 GAL TANK

CHECKED UPPER LINE ON 7-8-09 RA

CHECKED 2ND + 3RD LINES 7-16-09 RA

CHECKED REMAINING LINES 7-23-09 RA

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mos.*

Owner / Applicant Signature: Date

Improvement Permit by: Date 6-8-09

Authorization to Construct by: Date 6-8-09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: ROLLANS

Operation Permit by: RS Date: 7-23-09

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant