DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 2A 745
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jeff Mullens OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: Jan. 24, 94
PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: 1.533 Ac.
LOCATION OF SITE: Lot 5, West Paces
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-13	cl sbk	1:1 fr			1		.4-.5
		13-32	c sbk	1:1 fi			PS		.4
		32-38	sic vksbk	1:1 fi					.3
		38-48	sicl ak sbk	1:1 fr			1		.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: RHuman / RS OTHER(S) PRESENT: Duke Edmunton
COMMENTS: Site can be reclassified PS per rule .1956 modified system
RRBS