IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 315,00 Fa.d MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13054270 PIN# 4644 47 0801.000 DATE 9/7/05

OWNER OR CONTRACTOR Randolph + Kimberly Jordan PHONE: Business 704-948-9382 Home

ADDRESS 9427 Culcain Rd. Huntersville, NC. 28078

LOCATION 188 West Paces Rd. - 1155 TR Langtree Tl Mecklyn Rd TR West Paces

SUBDIVISION West View BLOCK / SECTION 4 LOT 22 LOT AREA .78 SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. .3

Septic Tank: 1500 ✓ Gallons; STB 338 Date 4/4/06
Pump Tank: 1500 Gallons; PT 477 Date 3/24/06
Pump Make: Model Serial No.
Nitrification Field: No Fields 1 Square Feet 582-998 Linear Feet 266
No Lines 3@90' Trench Width 2-3 Max Trench Bottom Depth Gravel Depth

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: LPP - 16" PPBRS
Repair System Description: SAME
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms 4
☐ Business No. Employees
☐ Other
☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: Fast Track from S+EC
For location and layout of system see S+EC Site Plan (see attached)

Comments:/Conditions:

INITIAL SITE SKETCH

See Attached Site Plans.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Kimberly B Jordan date 9-7-05 Installed by: Specialty Septic Tank

Improvement Permit by: Wesley Sparks R.S. date 9/7/05 Operation Permit by: Wesley Sparks R.S. date 11/16/06

Authorization to Construct by: Wesley Sparks R.S. date 9/7/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK