4645089327

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR C.W. Brewer DATE 6/22/88 PERMIT NO.

PHONE: Business Home

LOCATION 21 S. X I-77 TR Templeton Rd. TR Chestnut Hill Road 2nd lot on R. Irish Rd S. R. No.

SUBDIVISION NAME LOT NO. 32 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clayey
Percolation Rate v. 4 aged/ft²
Topography 4-6%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area

Basement with Plumbing ___ Basement without Plumbing ___ No Basement ✓



Plot of System N.T.S.

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Wayne Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY ACP

COMMENTS: Changed tank designed due to change of house plans (3 BR system). CW Brewer called 6-21-88.

CERTIFICATE OF COMPLETION BY Andrea C. Pierce DATE 6/22/88

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold