4645093057

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. K. Berringer DATE 4-2-80 PERMIT NO. 58

PHONE: Business _____ Home _____

LOCATION 1206 TRon 1108 TRon 1184 TRon 1203, 1 mi. on left _____ S. R. No. _____


SUBDIVISION NAME R. A. White LOT NO. 17 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 min-f	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-4%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none obs.	

Lot Area 3/4 AC+



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 525 Linear Ft. 175
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by H. J. Erwin

IMPROVEMENTS PERMIT BY IRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 4-2-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold