~~4654137307~~

IREDELL COUNTY HEALTH DEPARTMENT 4645137307

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR O'Malley DATE 4-23-74 PERMIT NO. 96

PHONE: Business _____ Home _____

LOCATION 115 South TR on 1102 Pass I-77 TR on 1202 next to last lot on right S. R. No. 1202

SUBDIVISION NAME Yeoman ~~Komen~~ Shores LOT NO. 2 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ acre


Character & Porosity of Soil Fine Sandy Clay loam Porosity Fair to Good

Percolation Rate not taken

Topography ~~Flat~~ 3% slope

Depth to Water Table 10' +

Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by J.R. Bowles

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Top of Tank is 3' underground

CERTIFICATE OF COMPLETION BY J.C. Moore DATE 4-23-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold