IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Paid 1030-2100 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 128172 PIN# 4645153684 DATE 5-25-05

OWNER OR CONTRACTOR Charles Welton / Phillip Thomas Contact Mike PHONE: Business 576-3887 Home

ADDRESS 1400 Harding Place Charlotte, NC 28204-2924

LOCATION Alcove Rd TR Templeton Rd TL Camino Real Rd TL Iron Gate Circle lot on right #166

SUBDIVISION Quail's Cove BLOCK / SECTION LOT 8 LOT AREA 1.041 Acre SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 1007 Date 2/17/06
Pump Tank: 1000 Gallons; PT 274 Date 1/9/06
Pump Make: Zoeller Model N98B Serial No.
Nitrification Field: No Fields 1 Square Feet 550' Linear Feet 275'
No Lines 5 Trench Width 24" Max Trench Bottom Depth 36" Gravel Depth N/A

X New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Pump - LP - Panel Block
Repair System Description: Same
Maintenance Agreement Required: X Yes ☐ No

X House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms
☐ Business No. Employees
☐ Other
☐ Slab X Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: X Individual ☐ Public ☐ Community

Comments:/Conditions: Septic Permit Approved for attached plan, designed by Michael Athanas LSS. Use "in-line" filter on pump.

INITIAL SITE SKETCH

See attached plan & drawing for Septic System Lay Out.

Comments:/Conditions: 4/26/06 - LW - okay to move tanks, 3/16" hole drilled, 1 line checked 5/5/06 Check 2, 3 & 4 lines 5/10/06 MD Checked 5th line & tanks 5/11/06 Pressure Checked 6/28/06 MD

AS BUILT SKETCH

Elect & alarm Checked 6/29/06

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 06/02/05 Installed by: Wayne Chontz

Improvement Permit by: Maria H. Dotson RS date 5/25/05 Operation Permit by: Maria H. Dotson RS date 6/29/06

Authorization to Construct by: Maria H. Dotson RS date 6/3/05 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK