IREDELL COUNTY HEALTH DEPARTMENT 4645 15 3839

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Curren DATE 7-26-84 PERMIT NO. 239

PHONE: Business _____ Home _____

LOCATION 21 South X 177 to TL 1206 TR 1108 Bear left on 1181 (Dead End) ½ mile on left S. R. No. _____

SUBDIVISION NAME The Cove LOT NO. 3 SECTION OR BLOCK NO. _____

(Irwin Bek Prop.) 162 Iron Gate


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (X) No ( )
Auto. Dishwasher Yes (X) No ( )
Auto. Wash. Machine Yes (X) No ( )
Site Suitable Yes (X) No ( )
Lot Area ½ ACRE

Character & Porosity of Soil Clay loam
Percolation Rate 0-60 4" Stabilized Rate
Topography _____
Depth to Water Table 4'6"
Rock or other impervious formations NONE OBS.

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by J. J. Erwin Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 7-26-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold