IREDELL COUNTY HEALTH DEPARTMENT 4645169168

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Thomas L. Christenbury DATE 12-23-81 PERMIT NO. 368

PHONE: Business _____ Home _____

LOCATION 21.5 X I 77 TL 1206 TR 1108 TL 1181 ~ 0.1 mile
TL Queens Cove TR. FORUM Drive NEAR END on left S. R. No. _____


SUBDIVISION NAME Queens Cove LOT NO. 124 SECTION OR BLOCK NO. III

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (X)	No ( )	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	~ 30 min per inch
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Level
Site Suitable	Yes (X)	No ( )	Depth to Water Table	4 ft
Lot Area 0.86 ACRE			Rock or other impervious formations	None observed

X Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1000 Linear Ft. 333'
Depth of Stone in Lines 16"
Water Supply: Individual (X)
Public ( )

Installed by J. R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 12-23-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold