"DEPARTMENT OF ENVIRONMENT,"
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ronald Talbott OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8/15/94
PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: 110' x 265'
LOCATION OF SITE: lot 4, Kelly Cove
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Borings ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1955 SAPRLT CLASS	HORIZON LTAR
1	55 ~4%	0-3	SAB / CL	1:1 / fr			PS		.5
		3-27	SAB / C	1:1 / Vfi					.35
		27-48	wk SAB / SIC	1:1 / fi					.3
2									
3									
4									
5									

AVAILABLE SPACE (.1948): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: DLHinson OTHER(S) PRESENT: Ron Talbott
COMMENTS: Conventional system space available w/ adjustment of house backwalls ~35'.