106 Bain Ln.

IREDELL COUNTY HEALTH DEPARTMENT 4645-22-0860

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Howell DATE 8-10-83 PERMIT NO. 268

PHONE: Business _____ Home _____

LOCATION 1102 TR 1202 0.2 mile on R before Payne Road (on corner) S. R. No. _____

SUBDIVISION NAME Yeoman Shores LOT NO. 1 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(X)	
Auto. Dishwasher	Yes	(X)	No	( )	
Auto. Wash. Machine	Yes	(X)	No	( )	
Site Suitable	Yes	(X)	No	( )	

Character & Porosity of Soil Clay loam
Percolation Rate 0.5 gal/ft²/day
Topography 5-10%
Depth to Water Table 4'+
Rock or other impervious formations NONE observed

Lot Area 2 ACRE

X Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by Self

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: (Payne Road) Meth Road East

_____

IREDELL COUNTY HEALTH DEPARTMENT

1:00

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Howell DATE 7-12-83 PERMIT NO. 179

PHONE: Business _____ Home _____

LOCATION 1102 TR 1202 .2 mile ONR before Payne Road (ON CORNER) S. R. No. _____

SUBDIVISION NAME Freeman Shores LOT NO. 1 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2


Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Character & Porosity of Soil Clay Loam Fill
Percolation Rate 0.5 Min/Inch
Topography 20% 4%
Depth to Water Table _____
Rock or other impervious formations NONE observed (to bedrock)

Lot Area N/A ACRE

(X) Basement with Plumbing ( ) Basement without Plumbing ( ) No Basement

1000 GALLON pump tank
SEALING TANK



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 18"

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Richard G Howell

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep drain field as shallow as possible About 1.0' to 1.5' cover. Must install Alarms and be working before final building inspection Approval; CROSS DRIVE with 10+ of ABS pipe

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold