IREDELL COUNTY HEALTH DEPARTMENT 4645223446

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Terry M. Ball DATE 4-26-83 PERMIT NO. 127

PHONE: Business _____ Home _____

LOCATION 1155 TR 1102 TR 1202 0.1 mile on R

SUBDIVISION NAME Yeoman Shores LOT NO. 5 S. R. No. _____ SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No	(X)
Auto. Dishwasher	Yes (X)	No	( )
Auto. Wash. Machine	Yes (X)	No	( )
Site Suitable	Yes (X)	No	( )

Lot Area 20,000+/-

Character & Porosity of Soil Clay loam 72"+ deep
Percolation Rate 0.5 gpf/day
Topography 10-15% slope
Depth to Water Table Unknown
Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Alexander County
Installed by Tom Cothren

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY D. R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Jack Clanton DATE 4-26-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold