4645232506 Type II

Charles Barnett 1:00-1:15

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Madry Construction Co. DATE 9-30-85 PERMIT NO. 333

PHONE: Business _____ Home _____

LOCATION 1102 Langtree Lane TR on Yoeman Lane go 5.3 around the curve (BR) lot near end on left S. R. No. _____

SUBDIVISION NAME Yoeman Shores LOT NO. 5 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 20,000+/-

Character & Porosity of Soil C/a
Percolation Rate 0.5 gal/ft²/day
Topography 2-8%
Depth to Water Table 4'
Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"
Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: * Paul Sox Phillips

IMPROVEMENTS PERMIT BY Charles K. Barnett

COMMENTS: Deep system shallow follow contour

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold