DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Gary Johnston
ADDRESS: ___ APPLICANT: ___
PROPOSED FACILITY: ___ APPLICATION DATE: ___ DATE EVALUATED: 9/30/02
LOCATION OF SITE: Lot 4 Beaman PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: 1+/-
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	AH-1 In Front	0-3"	Brw to Rd/Brw SCL w/SBK		SS,SP,SE,FR				PS .31+
		3"-30"	Rd/Brw C/CL m-w SBK						
		30-48"	Rd/Brw C/CL w/SBK		SS,SP,SE,FR w/Few to many Common Mica Flakes				
			SAP Indus						
2	AH-2 In Back	0-12"	Brw SCL w/SBK		SS,SP,SE,FT-FR				PS .31+
		12"-30"	Rd/Brw C/CL m-w SBK						
		30"-48"	Rd to Rd/Bel w/SBK		SS,SP,SE FR w/Some SAP				
			Indus Ca/Common Mica Flakes						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___

HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Joseph Kronk
ADDRESS: ___ OWNER: ___ AGENT: ___ PHONE: ___
APPLICATION DATE: ___ DATE EVALUATED: 7/6/94
PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE: 100'x230'
LOCATION OF SITE: Bain Lane, lot 12, Yeomen Shores
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS	0-30	SAb/C	1:1/fi-vfi			PS		.35
		30+48	wkSAb/sic	1:1/fi			PS		.3
2									
3									
4									
5									

SUITABLE SPACE (.1945): ~~PS~~ SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DRobinson RS OTHER(S) PRESENT: Chuck Masterson (Blue Water Realty) SITE LONG-TERM ACCEPTANCE RATE: .3
COMMENTS: * Site recorded prior to 1983. Repair area to be for LPP BBS