4645-26-0870

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Sacosky DATE 7/5/90 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 1206 TR 1108 (Templeton) Bear left Camino Real TL into Queens Cove Bear right on Forum Dr, on right S. R. No. _____

SUBDIVISION NAME Queens Cove LOT NO. 129 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 4	No. Bathrooms 2½	Character & Porosity of Soil	clay
Garbage Disposal Unit	Yes (✓) No ( )	Percolation Rate	2.4
Auto. Dishwasher	Yes (✓) No ( )	Topography	4-6%
Auto. Wash. Machine	Yes (✓) No ( )	Depth to Water Table	4'
Site ~~Suitable~~ OS	Yes (✓) No ( )	Rock or other impervious formations	none obs.
Lot Area Lge			

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Paul Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: 60' Solid pipe from Bull Run to Drop Box
Solid line above old drainfield

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE 7/5/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold