12108

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bob McLemore Builders DATE Oct. 19, '90 PERMIT NO. 26-21-A1

PHONE: Business _____ Home _____

LOCATION 1206 (Alcove) TR 1108 (Templeton Rd.) past Camino Road ~ 1/8-1/4 mile on right TR into Morgan Landing 1st house on left S. R. No. _____

SUBDIVISION NAME Morgan Landing LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site ~~Suitable~~ PS Yes (✓) No ( )

Lot Area 20000 ft²+

Character & Porosity of Soil mid-low range SC clay (Caston/Lloyd)

Percolation Rate 20 25


Topography 2-4%

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1250+ pump tank



Plot of System

Size of Tank 1250+ Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. _____ Linear Ft. 240' ±

Depth of Stone in Lines 16" to 20"

Water Supply: Individual (✓) Public ( )

panels pressure dosed

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David R. Hinson, EHS

COMMENTS: follow contour. 30" maximum trench bottom depth.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold