DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Mark (Marie Mayhew) APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 2-22-
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 15 Sunset Lane PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 1-6%	0-7	sdy brwn L	(brown)					PS .3
		7-23	sdy cl	L-sp 11					
		23-48	wk-mk sdy brwn L						
			lawn mottles						
			few gravel w/ fines						
2	L 4-6%	0-13	V brwn sdl						PS .34
		13-23	sdy cl						
		23-40	mottled RCL few gravel fines						
		40	Hard rock @ 40in (Knob)						
3	4-9-98 AH	0-15	sdy RCL/CL few sp ssfp						PS -3
		15-48	wt sdy RCL - few ssfp soil						
			increasing mott'g w/ depth						
			sap @ 36-40"+						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

2 Soil sites where needs to be flagged
Undisturbed area above site
Appears suitable for conventional system upon lot inspection
Lot used @ 50' wide