DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert E Jacks Jr. OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7/11/94
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: .74 ac
LOCATION OF SITE: Lot 22, Carson Place
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	SS 4-6%	0-23"	SAB / C	1:1 / fi-vfi			PS		.3
		23-48	wkSAB / sic	1:1 / fi					
2									
3									
4									
5									

AVAILABLE SPACE (.1945) U * SITE CLASSIFICATION (.1948): PS * SITE LONG-TERM ACCEPTANCE RATE .3
EVALUATED BY: DRHuffman, RS OTHER(S) PRESENT: R. E Jacks
COMMENTS: * Site can be reclassified PS per rule .1956 Modified systems OPBPS