11-30-12 Co

14904

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Larry Chuslo DATE July 16 '92 PERMIT NO. 246A14

PHONE: Business _____ Home _____

LOCATION 115 S. TR 1102 (Longtree) TR into Carson's Place
Bear right at end on left S.R. No. _____

SUBDIVISION NAME Carson's Place LOT NO. 18 SECTION OR BLOCK NO. _____


House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes ☐ No ☑
Auto. Dishwasher Yes ☑ No ☐
Auto. Wash. Machine Yes ☑ No ☐
Lot Area ≥ 20,000 ft²

Soil Characteristics psclay
Application Rate .3 gal/ft²/day
Topography ~6%
Depth to Water Table ≥ 4'
Rock or other impervious formations none obs.

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 / 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. _____ Linear Ft. 200'
Depth of Stone in Lines of 16"
Water Supply: Individual ☑ PPBS
Public ☐

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: X _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

LP Panel Repair Area Here

IMPROVEMENT PERMIT BY D.L. Hunsucker, RS.

COMMENTS * Maintenance agreement required prior to issuance of Operations Permit
Follow contour with drainfield. 36" maximum trench bottom depth.
46 panels total, one 3/16 hole per panel located in middle of panel turned up. Pump specs: 28 gal/min at Approx. 30' head

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold