96134

IREDELL COUNTY HEALTH DEPARTMENT 4645-34-1894

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph H. Rowe DATE Nov. 25 '87 PERMIT NO.

PHONE: Business Home

LOCATION 1296 (Alcove) SR 1108 (Templeton) N main entrance of Queen's Cove Brick at water front on left S. R. No.

SUBDIVISION NAME Queen's Cove LOT NO. 18 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other


No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20000ft² +

Character & Porosity of Soil clay
Percolation Rate 2.35
Topography 2-4%
Depth to Water Table 4ft (2' below gravels)
Rock or other impervious formations none obs.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. Linear Ft. 230'
Depth of Stone in Lines 16" to 20"
Water Supply: Individual (✓) gravels pretty Public ( ) Plow

Installed by R. Dobson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY DRH

COMMENTS:

CERTIFICATE OF COMPLETION BY D.R. Hanson, R.S.

EXISTING SYSTEM CHECKED BY: DATE 11-25-87

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold