IREDELL COUNTY HEALTH DEPARTMENT 4645-35-8371

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Custom Kitchens Inc. DATE 6-13-84 PERMIT NO. 180

PHONE: Business _____ Home _____

LOCATION 21S, XI77 TL 1206 TR 1108 TL Queen's Cove, go to H_2O bear left lot on R

S. R. No. _____

SUBDIVISION NAME Queen's Cove LOT NO. 9 SECTION OR BLOCK NO. I


House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes (X)	No ( )	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area 30,000 ft²

Character & Porosity of Soil clay loam
Percolation Rate .3 gal/ft²/day
Topography 2-8%
Depth to Water Table 4'
Rock or other impervious formations None observed
use 1st ft of washed sand under panels
1500



Plot of System

Size of Tank ~~1000~~ Gals.

Nitrification Field:
No. of Lines 150 LFT 24"
Sq. Ft. _____ Linear Ft. T45 panels

Depth of Stone in Lines _____

Water Supply: Individual (X)
Public ( )

Lake

Installed by Orbison

I understand and agree to install septic tank system as specified on this Improvements Permit.

Lake

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles K. Barnett & Fred Clemmer DATE 6-13-84

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold