DIVISION OF ENVIRONMENTAL HEALTH — NATURAL RESOURCES
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

# SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: Mark Young
ADDRESS: 155 Queens Court Rd
APPLICANT: Same
PROPOSED FACILITY: House
APPLICATION DATE:
LOCATION OF SITE: Lot 2 Queens Court
PROPOSED DESIGN FLOW (.1949): 480 GPD
DATE EVALUATED: 2/23/05
PROPERTY SIZE: 2.246 acres
PROPERTY RECORDED: Y
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

| PROFILE # | .1940 LAND-SCAPE POSITION/ SLOPE % | HORI-ZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | T 3-5% mwp | 0-10 | SSbk / l-scl | Fri SS - SP | PS / BR | | | | |
| | | 11-30 | SBk / c | Fri S - SP | PS / R | | | | |
| | | 31-49 | mSBk / hcl | Fri SS - SP | DBY / R | | | | |
| | | 50- | Sap. | Fri ~mica | DRY | | ↓PS | | ↑1.25 |
| 2 | T 5-6 mwp | 6-10 | FSBk / l-sl | VFri SS - NP | PS / BR | | | | |
| | | 11-33 | FSBk/hcl | Fri S - SP | PS / R | | | | |
| | | 34-52 | FSBk / cl | VFri SS - SP Restrictive depth | M / MP | | PS | | ↓.35 |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| vailable Space (.1945) | P | |
| /stem Type(s) | Conv 25% | 25% |
| te LTAR | .6 | |

OTHER FACTORS (.1946): Frontyard lined - need tenacity
SITE CLASSIFICATION (.1948):
EVALUATED BY:
OTHER(S) PRESENT: