Department of Environment, Health, and Natural Resources
Division of Environmental Health
On-site Wastewater Section

Sheet: 1 OF 1
PIN #: 4645-36-4730
Lot #: 35
Permit #: 171903
AppID:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: DAVID DENNIS
Applicant: SAME
Address: 000 HARWELL RD
Date Evaluated: 5/11/2012
Proposed Facility: SFR
Design Flow (.1949) 480
Property Size: 1.931 AC
Location of Site: QUEENS COVE SECTION 2 LOT 35
Property Recorded: YES
Water Supply: [ ] Public [X] Individual [X] Well [ ] Spring [ ] Other
Evaluation Method: [X] Auger Boring [ ] Pit [ ] Cut
Type of Wastewater: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941 .1941 Structure/ Texture	.1941 Consistence Mineralogy	b PROFILE FACTORS .1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
AB 1	LINEAR 4%	0-27	CL,M,SBK	SS,VFR	NA	48"	NA	48"+	.3
		27-48	C,M,SBK	SS,FR					
AB 2	LINEAR 4%	0-39	CL,M,SBK	SS,VFR	NA	48"	NA	48"+	.3
		39-48	C,M,SBK	SS,FR					
AB 3	LINEAR 4%	0-33	CL,M,SBK	SS,VFR	NA	48"	NA	48"+	.3
		33-48	C,M,SBK	SS,FR					
AB 4	LINEAR 4%	0-36	CL,M,SBK	SS,VFR	NA	48"	NA	48"+	.3
		36-48	C,M,SBK	SS,FR					

Description	Initial System	Repair System
Available Space (.1945)	PS	PS
System Type(s)	G-25%	G-25%
Site LTAR	.3	.3

Other Factors (.1946):
Soil Evaluation By: BEN ALDRIDGE
Others Present: DAVID DENNIS
Site Classification (.1948): PS
Site Evaluation By: BEN ALDRIDGE
Others Present: DAVID DENNIS