DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2H-18-A-6
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Craig Roseman OWNER: AGENT: ✓ PHONE: 896-0773
ADDRESS: 9710 Shenandoah Rd. APPLICATION DATE: 6/14/93 DATE EVALUATED: 6/15/93
Huntersville PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: 40,000 ft²+
LOCATION OF SITE: Alcove Rd. & Wades Way extend
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-6"	sbk CL	1:1 fr	NONE	NONE	PS	—	.3
		6-48"	wksbksicl	1:1 fr	NONE	NONE	PS	—	.2-.3
2	SS	0-2"	sbk cl	1:1 fr	NONE	NONE	PS	—	.4
		2-36"	sbk c	1:1 fr.	NONE	NONE	PS	—	.35
		36-48	sbk cl	1:1 fr.	NONE	NONE	PS	—	.3
3									
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] IRS OTHER(S) PRESENT: Craig Roseman, "Little" Hawkins
COMMENTS: