DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Jeff Jenske
ADDRESS: ___ OWNER: ___ AGENT: ___ PHONE: ___
APPLICATION DATE: ___ DATE EVALUATED: 3/10/94
PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: 2 AC
LOCATION OF SITE: Lot 6, Queens Cove
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | LS | 0-9 | SAB/CL | 1:1/fr | 1 | 2 | PS | | .4 |
| | | 9-26 | SAB/C | 1:1/vfi | | | | | .3 |
| | | 26-45+ | SAB/CL | 1:1/fr-fi | | | | | .35 |
| 2 | LS | 0-7 | SAB/CL | 1:1/fr | 2 | 2 | PS | | .4 |
| | | 7-40 | SAB/C | 1:1/vfi | | | | | .3 |
| | | 40+ | WSAB/CL | 1:1/fi | | | | | .3 |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1943): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [illegible] OTHER(S) PRESENT: Jeff Jenske
COMMENTS: ___