08795

IREDELL COUNTY HEALTH DEPARTMENT 4645-46-9700

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Modlin Bldg. Co. DATE Sept. 14, '88 PERMIT NO. 21C

PHONE: Business _____ Home _____

LOCATION 215 X I77 TL 206 (Above) TR Perrin Drive on left corner lot at Perrin Drive and Water's Edge Court S. R. No. _____

SUBDIVISION NAME Water's Edge LOT NO. 31 SECTION OR BLOCK NO. 3

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2


Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Shallow clay
Percolation Rate 20/3
Topography 4-5%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 157 x 300'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

1250 pump tank



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by J.R. Fowler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Alarm cred - 9-15-88 ACP

CERTIFICATE OF COMPLETION BY Andre C. Price DATE 9/15/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold