HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Doncreek OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE: 4.3 acres
LOCATION OF SITE: Queens Cove lot 9
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear 6 to 10%	0 to 8"	L	GR		.1942 WETNES CONDITION - N/A
		8 to 24"	C	5 SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 36"	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48"	CL	weak Blocky	1:1	.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	linear 6 to 9%	0 to 10"	L	GR		.1942 WETNES CONDITION - N/A
		10 to 36"	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48"	CL	weak Blocky	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	linear 6 to 9%	0 to 12"	L	GR		.1942 WETNESS CONDITION - N/A
		12 to 24"	C	weak SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 48"	CL	weak Blocky	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .32
4	linear 4 to 6%	0 to 12"	L	GR		.1942 WETNESS CONDITION - N/A
		12 to 32"	C	weak SBK	1:1	.1943/.1956 SAPROLITE - N/A
		32 to 48"	CL	weak Blocky	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .32
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
					PS	PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .32
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Jon Grigorian
COMMENTS: