10857

The proposed / existing COVERD PORCH addition does not appear to impact the existing septic system.
**NOTE: FOUNDATION MUST BE 5' FROM TANK

Date: 5-10-09
ICHD-Environmental Health Division

#64556231

(SEPTIC
(Ground Absorption Sewage

COMPLETION
Article 13C)


OWNER OR CONTRACTOR Alex Persons
PHONE: Business Home
DATE June 6, 90 PERMIT NO. 24-12-A-
LOCATION 215. X 177 TL 1206 (Alcove) TR Leuven Drive
on right in Cynne
SUBDIVISION NAME Waters Edge LOT NO. 101 S. R. No.
SECTION OR BLOCK NO.

House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil PS clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate fast 3
Auto. Wash. Machine	Yes ( )	No ( )	Topography mod
Site ~~Suitable~~ PS	Yes ( )	No ( )	Depth to Water Table 4' +
Lot Area 20x20 Ac			Rock or other impervious formations none obs.

Basement with Plumbing Basement without Plumbing No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. Linear Ft. 200 ft
Depth of Stone in Lines 16" to 24"
Water Supply: Individual ( ) panels
Public ( )

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY

SEE NEW SITE PLAN FOR UPDATE

COMMENTS: Plumbing pulled out high enough along with shaping (topo modification) on side of house to eliminate pump.

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY:

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

DATE June 6, 1990

DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: