IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Joseph Cody DATE 7-21-80 PERMIT NO. 218

PHONE: Business _____ Home _____

LOCATION 215 X I-77 : TL 1206 ~1 Mile TR into Perry Waters property S. R. No. _____

SUBDIVISION NAME Waters Cdy LOT NO. 7A SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	30 min - 120 min
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Good
Site Suitable	Yes (X)	No ( )	Depth to Water Table	3' +
			Rock or other impervious formations	None Observed

Lot Area ~1 Acre

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (X)
Public ( )
Mt. Pleasant

Installed by C.M. Barnes

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 7-21-80

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold