4645564456

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gary D. Ward DATE 5-23-85 PERMIT NO. 229

PHONE: Business _____ Home _____

LOCATION 21 & I 77 to 206 ½ mile on R TR Jerrin Drive Lot on R

SUBDIVISION NAME Waters Edge LOT NO. 8 S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____ SECTION OR BLOCK NO. _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 1.99 ACRE

Character & Porosity of Soil Stony Clay Loam


Percolation Rate 0.5 gal/ft²/day

Topography Slope

Depth to Water Table 4'6"

Rock or other impervious formations NONE obs

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 220 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by T. J. Ervin Co

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Jack Clemmer

COMMENTS: 10' Lot Line

CERTIFICATE OF COMPLETION BY Jack Clemmer DATE 5-23-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink