4645566570

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry W. Kistler DATE 10-20-80 PERMIT NO. 323

PHONE: Business _____ Home _____

LOCATION 215 to I-77 N 1306 aft Knox R Waters Edge Drive 4th Lot on R

SUBDIVISION NAME Waters Edge LOT NO. 9 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)
Auto. Dishwasher	Yes (X)	No ( )
Auto. Wash. Machine	Yes (X)	No ( )
Site Suitable	Yes (X)	No ( )

Lot Area 1.06 Acres

Character & Porosity of Soil Clay loam


Percolation Rate 100 mpi

Topography 2-4%

Depth to Water Table unknown

Rock or other impervious formations None Observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (X)

Public ( )

Installed by F. J. Cuneo Co

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: House Not wired for disposal due to poor soil

CERTIFICATE OF COMPLETION BY Fred Clemmer

EXISTING SYSTEM CHECKED BY: _____ DATE 10-20-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit. DATE _____

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold